

## **Multifunctional single-layer coating on a base of silicon Sylgard-184 elastomer**

V.G. Borisenko, E.V. Timakov, L.A. Andryushchenko, A.M. Kudin,  
M.M. Goroneskul

*National University for Civil Defence of Ukraine,  
94 Chernyshevskya Str., Kharkiv 61023, Ukraine, vitgbor7@gmail.com*

Silicone elastomer coatings are widely used to protect substrates from the negative effects of the atmosphere, especially fabrics, among which particularly stringent requirements are placed on the woven frame of a fire hose. In the last decade, there has been great interest in the development of polymer coatings that can simultaneously perform several functions, such as heat and fire protection, waterproofing, luminescent film, *etc.* The decorative function is also important, it is highly desirable that fire hoses have a bright color and were clearly visible under artificial lighting. As a rule, the protective coating is multilayer, each sublayer performs a specific function [1]. Such a coating structure leads to an increase in film thickness and product weight. Development of multifunctional protective coatings of minimum thickness is an urgent problem of modern technology [2].

It has been shown that number of sublayers in protective film can be reduced to one by combining several functions. It means that under certain conditions the thickness and weight of coating can be minimized. On a base of Sylgard-184 silicon elastomer a composition for single-layer protective coating is proposed for fire hoses. This composition contains Coumarin-7 as a luminescence dopant and a filler in form of halloysite nanotubes as an adhesion promoter.

It has been shown that proposed coating successfully protect the substrate against negative effects of UV-light and atmosphere oxygen and ozone. In addition to the protective function, such a coating successfully performs the function of a fire-retardant layer, a bright yellow decor, an adhesion promoter that prevents the coating from peeling off the lining, as well as a fluorescent film of green emission.

It is shown that the mechanical characteristics of the obtained samples do not change after climatic tests. This result, together with the improvement of the adhesion, as well as high weather and fire resistance of the samples, allows us to predict an increase in the service life of the fire hoses.

1. L. Andryushchenko, V. Borisenko, M. Goroneskul, A. Kudin. Emergency situations: prevention and elimination. **5**(2) (2021) 5.
2. M.M. Goroneskul, L.A. Andryushchenko, A.M. Kudin, *et al.* Method of application of luminescence coating. Patent 147605 UA. Bul. No **21** (26.05.2021).